



SECTION A - A

NOTE:

1. THE CASING SPACER SHALL BE THE CENTERED AND RESTRAINED TYPE.
2. THE SPACER BANDS SHALL BE STAINLESS STEEL.
3. ALL FASTENER HARDWARE (i.e. NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE CASING SPACERS SHALL BE STAINLESS STEEL.
4. THE SPACERS SHALL BE STAINLESS STEEL OR VILLAGE APPROVED EQUAL.



VILLAGE OF WHEELING
ENGINEERING DIVISION
2 COMMUNITY BOULEVARD
WHEELING, IL 60090
WWW.WHEELINGIL.GOV

**UNDERGROUND UTILITY
CASING PIPE STANDARD**

VILLAGE OF WHEELING SPECIFICATIONS AND DETAILS	REVISIONS		DETAIL NO.
	FILE LOCATION	S.W.	
T:\ENGINEERING\STANDARDS	S.W.	6-11-04 SPACER RQRMT.	
	K.R.G.	9-11-06 AUTOCAD FILE	