



NOTES:

1. TO BE FORMED WITH 2" x 6" BOARDS OR STEEL FORMS.
2. TOOLED JOINTS SHALL BE 1/2".
3. EXPANSION JOINTS SHALL BE 3/4" BITUMINOUS IMPREGNATED FIBERBOARD, AT DRIVEWAYS AND OTHER CONCRETE JOINTS.
4. PROVIDE BROOM FINISH.
5. D = 5" MINIMUM THICKNESS FOR ALL RESIDENTIAL WALKS & PATIOS
6. ALL SERVICE WALKS AND PATIOS SHALL BE BUILT PER THE VILLAGE OF WHEELING STANDARDS.
7. THE CONCRETE SHALL BE A 6 BAG MIX AND SHALL **NOT** CONTAIN CHLORIDE.
8. COMPACTED STONE BASE SHALL BE (CA-6, GRADE 8 OR GRADE 9) VIRGIN MATERIAL ONLY OR VILLAGE ENGINEER APPROVED EQUAL.



VILLAGE OF WHEELING
ENGINEERING DIVISION
2 COMMUNITY BOULEVARD
WHEELING, IL 60090
WWW.WHEELINGIL.GOV

**SERVICE WALK AND PATIO
STANDARD**

VILLAGE OF WHEELING
SPECIFICATIONS AND DETAILS
FILE LOCATION
T:\ENGINEERING\STANDARDS

REVISIONS		
W.F.H.	10-04-04	AUTOCAD FILE
S.W.	03-23-05	COMMENTS BY GK
C.J.C.	11-27-07	AUTOCAD FILE

DETAIL NO.
R-4