



PROPOSED/EXISTING PAVEMENT GRADE

CAST IRON INSPECTION FRAME, SOLID LIDS FRAME & COVER NEENAH R-1970-78 SERIES OR EQUAL IN PAVEMENT

REPLACE IN KIND, MUST MEET VILLAGE OF WHEELING DRIVEWAY STANDARDS FOR ENCASING PIPE WHEN INSTALLED IN PAVEMENT (NOT REQUIRED FOR RESIDENTIAL COVERS IN GRASS)

SCREW ON COVER

6" DIA.

**NOTES:**

1. USE NON-SHEAR COUPLINGS TO MAKE CONNECTIONS TO DISSIMILAR PIPE MATERIALS.
2. CLEANOUT PIPE, TEE AND ENLARGING COUPLING SHALL BE P.V.C. SDR 26, P.V.C. SCHEDULE 40, D.I.P. CLASS 52 OR VILLAGE ENGINEER APPROVED EQUAL.
3. ALL SERVICE LINES SHALL EXIT THE FOUNDATION WALL, AS DIP AT A RIGHT ANGLE (90 DEGREES) AND MUST BE OF SUFFICIENT DEPTH, ALONG ITS LENGTH, TO PROVIDE A MINIMUM COVER OVER THE TOP OF THE PIPE OF 3-1/2 FEET.

5' MIN.

CHANGE IN PIPE SIZE SHALL OCCUR BEFORE TEE CONNECTION. AN ENLARGING COUPLING WILL BE REQUIRED PER VILLAGE PLUMBING INSPECTOR

FOUNDATION WALL

4" MIN. PIPE RESIDENTIAL PER VILLAGE PLUMBING INSPECTOR

FLOW

TEE

FLOW

NON-SHEAR COUPLING

SEE PLAN FOR PIPE SIZE, 6" MIN. REQUIRED

SANITARY SERVICE DUCTILE IRON PIPE REQUIRED THROUGH FOUNDATION WALL

VILLAGE OF WHEELING SPECIFICATIONS AND DETAILS	
FILE LOCATION	
T:\ENGINEERING\STANDARDS	



VILLAGE OF WHEELING  
ENGINEERING DIVISION  
2 COMMUNITY BOULEVARD  
WHEELING, IL 60090  
WWW.WHEELINGIL.GOV

## SANITARY SEWER CLEANOUT STANDARD

REVISIONS	
C.J.C.	11-27-07 AUTOCAD FILE
C.J.C.	08-08-08 VILLAGE REVISIONS
K.R.G.	08-31-11 TEE REVISIONS

DETAIL NO.
SAN-6